



Janet T. Mills
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Bruce A. Van Note
COMMISSIONER

October 24, 2019
Subject: Gilman Bridge Replacement
State WIN: 018952.00
Location: **Athens**
Amendment No. 1

Dear Sir/Ms.:

The following question has been received:

Question: Would Method D testing be allowed for the paving on this project? If so how many cores and samples would there be per item?

Response: No, the testing method shall be Method B, as defined in SPECIAL PROVISION – SECTION 403 HOT MIX ASPHALT PAVEMENT.

Consider these changes and information prior to submitting your bid on **November 6, 2019**.

Sincerely,

George M. A. Macdougall P.E.
Contracts & Specifications Engineer